

PUBLIC ANNOUNCEMENT



Dear Valued Customer,

We sincerely apologise for not meeting up with the required minimum service level of 20 hours on the feeders below.

Date: 06/07/2024

Transmission Station	Feeder_33kV	Injection Substation	Feeder_11kV	Band	Region	6th July 2024				
						Reason for Outage	Outage on Under Frequency/TCN Related (hrs)	BEDC Outages (hrs)	Total Duration of Outage (hrs)	Availability (Hrs)
BENIN	ETETE	C/HOME INJ S/S	LIMIT ROAD COMMERCIAL	A	BENIN SOUTH	System Collapse and Transient fault	3.50	1.50	5.00	19.00
BENIN	NEKPENKPEN	NEKP. INJ S/S	AKPAKPAVA COMMERCIAL	A	BENIN SOUTH	System Collapse and Planned Outage on Nekpenekpen 33kv feeder	4.08	1.19	5.27	18.73
IHOVBOR	UNIBEN	UNIBEN INJ S/S	UNIBEN COMMERCIAL	A	BENIN NORTH	Faulty Power Transformer		24.00	24.00	-
AGBOR	AGBOR 6	AGBOR MAIN INJ S/S	JAMES HOPE COMMERCIAL	A	ASABA	System Collapse and Over current fault	6.43	1.27	7.70	16.30
ASABA	OGWASHI-UKU	OGWASHI-UKU 1X7.5	OGWASHI-UKU COMMERCIAL	A	ASABA	System Collapse	6.85		6.85	17.15
AMUKPE	MOSOGAR	AMOKPE INJ S/S	AMUKPE COMMERCIAL	A	SAPELE	System Collapse	7.08		7.08	16.92
AKURE	AKURE	ILESHA RD INJ S/S	ROYAL - COMMERCIAL	A	ONDO	System Collapse	5.00		5.00	19.00
AKURE	OBAILE/REC	OBAILE INJ S/S	AKURE - COMMERCIAL	A	AKURE	System Collapse and Fault on Obaile/Rec 33KV feeder	5.00	0.92	5.92	18.08
BENIN	STEEL COMPANY 1			A	BENIN SOUTH	System Collapse	9.00		9.00	15.00

PUBLIC ANNOUNCEMENT



Transmission Station	Feeder_33kV	Injection Substation	Feeder_11kV	Band	Region	6th July 2024				
						Reason for Outage	Outage on Under Frequency/TCN Related (hrs)	BEDC Outages (hrs)	Total Duration of Outage (hrs)	Availability (Hrs)
BENIN	STEEL COMPANY 2			A	BENIN SOUTH	System Collapse	9.00		9.00	15.00
BENIN	GUINNESS			A	BENIN NORTH	System Collapse	5.00		5.00	19.00
OKPELLA	CEMENT FACTORY			A	AUCHI	On disconnection for non-payment		24.00	24.00	-
ASABA	GSM			A	ASABA	System Collapse	6.00		6.00	18.00
ASABA	EASTERN METAL			A	ASABA	System Collapse	6.00		6.00	18.00
AMUKPE	WOODLAND			A	SAPELE	System Collapse	7.00		7.00	17.00
OGHARA	OGHARA TEACHING HOSPITAL			A	SAPELE	System Collapse and VT issue	8.00	6.00	14.00	10.00
DELTA	IMONIYAME			A	WARRI	On disconnection for non-payment		24.00	24.00	-
OMOTOSHO	RUBBER ESTATE			A	ONDO	System Collapse	6.00		6.00	18.00
AKURE	FUTA			A	ONDO	System Collapse	5.00		5.00	19.00
ETSAKO	AGHOR			A	AUCHI	System Collapse and Earth fault	4.92	0.08	5.00	19.00
AMUKPE	MOSOGAR			A	SAPELE	System Collapse	7.00		7.00	17.00
AGBOR	AGBOR 6			A	ASABA	System Collapse	6.00		6.00	18.00
ADO EKITI	ADO			A	EKITI	System Collapse	5.00		5.00	19.00
AKURE	OBA-ILE/REC			A	AKURE	System Collapse and Earth fault	5.00	0.92	5.92	18.08
AMUKPE	INDUSTRIAL			A	SAPELE	System Collapse	7.00		7.00	17.00
AMUKPE	SAPELE (SAPELE)			A	SAPELE	System Collapse	7.00		7.00	17.00
ASABA	OGWASHI-UKU			A	ASABA	System Collapse	6.00		6.00	18.00
IHOVBOR	UNIBEN			A	BENIN NORTH	System Collapse	5.00		5.00	19.00
ASABA	ISELE-UKU	OKPANAM INJ S/S	OKPANAM COMMERCIAL	A	ASABA	System Collapse	7.18		7.18	16.82
ASABA	ISELE-UKU			A	ASABA	System Collapse	6.00		6.00	18.00
ADO EKITI	AFF-BABALOLA			A	EKITI	System Collapse	5.00		5.00	19.00



PUBLIC ANNOUNCEMENT

We are taking steps to ensure consistent and reliable power supply in the affected areas. BEDC is committed to upholding service level agreements.

Thank you for choosing BEDC.

Signed,
Management
06/07/2024

www.beninelectric.com | +234 700 000 2332 | Customercomplaints@beninelectric.com

